

WATER COOLING SERIES

REFRIGERATED AIR DRYER



Refrigerated Air Dryer

Water-cooling

Inlet temperature: High inlet temperature < 80°C

Cooling method: Water-cooling

Design dew point: 2-10°C

Refrigerant: R-22 and R134A, R404A, R407

Inlet pressure: 6-40bar

Pressure drop: <0.2bar

Cooling water inlet temperature: < 32°C

Cooling water inlet pressure: 2~4bar



Technical Data

Model	Flow Capacity	Conn.	Dimensions mm			Weight
	M3/min		L	W	H	Kg
Refrigerated air dryer						
BT-2F	2.6	ZG1"	700	450	915	80
BT-4F	4	ZG1 1/2"	850	500	970	105
BT-5F	5.2	ZG1 1/2"	850	500	970	135
BT-7F	7	ZG1 1/2"	900	560	1070	190
BT-8F	8.5	ZG1 1/2"	900	560	1070	195
BT-11F	11	ZG2"	1180	670	1160	225
BT-13F	13.8	ZG2"	1180	670	1160	260
BT-16F	16	ZG2"	1180	670	1160	305
BT-20F	20	DN80	1360	710	1205	400
BT-25F	25	DN80	1650	970	1422	520
BT-35F	35	DN80	1650	970	1422	630
BT-45F	45	DN100	1810	1090	1697	750
BT-55F	55	DN125	2245	1410	1955	870
BT-17W	17	DN80	1560	1118	1340	420
BT-23W	23	DN80	1600	1110	1486	470
BT-27W	27	DN80	1805	1110	1510	590
BT-33W	33	DN80	1950	1283	1700	680
BT-45W	45	DN100	2250	1285	1683	785
BT-55W	55	DN125	2130	1350	1708	870
BT-65W	65	DN125	2310	1430	1708	1100
BT-85W	85	DN125	2460	1440	1893	1700
BT-100W	100	DN150	2860	1620	2000	2480
BT-120W	120	DN150	2960	1620	2030	2520
BT-150W	150	DN200	2960	1620	2050	2800
BT-200W	200	DN200	3130	2090	2470	3360
BT-300W	300	DN250	3800	2470	2959	3920



HEAD OFFICE JAKARTA :

Komplek Gading Bukit Indah Blok V No. 23
Kelapa Gading - Jakarta Utara 14240
Indonesia
Telp : 021-29382790

BRANCH OFFICE BANDUNG :

Taman Holis Indah Blok E4 No. 21
Kel. Cigondewah Kidul Kec. Bandung Kulon
Bandung, Jawa Barat 40214
Indonesia
Telp : 022-20573429

BRANCH OFFICE SOLO :

Jl. Raya Solo Sragen KM.15 Dukuh Nglarangan RT.03/RW.01
Kel.Kebak, Kec. Kebakramat, Kab.Karanganyar, Jawa Tengah 57762
Indonesia
Telp : +62 271 601 2023

WORKSHOP :

Pergudangan Central Cakung Business PArk
Blok D No. 11 Jl. Cakung Cilincing Timur KM 3
Jakarta Utara 14140
Indonesia